



Certificate of Compliance

Certificate: 1268939

Master Contract: 213839

Project: 1268939

Date Issued: December 4, 2001

Issued to: **STL Transtech Limited**
64/66 Percy Rd.
Aylestone Park
Leicester, LE2 8FN
UNITED KINGDOM

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: G. Foulem, E.I.T.

PRODUCTS

CLASS 5311 04 - POWER SUPPLIES - Battery Chargers

CLASS 5311 84 - POWER SUPPLIES - Battery Chargers - CERTIFIED TO U.S. STANDARDS

Automatic non-automotive battery charger, cord-connected,

Model 12XXAXXXUXXXXXX, 110/120V, 60Hz, 1A; output 12V, 4A dc max.

Model 24XXAXXXUXXXXXX, 110/120V, 60Hz, 1.2A; output 24V, 2A dc max.

Notes:

1. For use only with sealed lead-acid type batteries.
2. X, may be different numbers or letters, see part numbering systems Ills. 1 and 2.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 107.2-M89

- Battery Chargers

UL Std No. 1012

- Power Units Other Than Class 2, Sixth Edition, May 24, 2000

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.